



Türkiye

Attestation of Compliance

TYPE TEST of components and systems

Certificate no :	Z-IS-TGK-13-B-00816/01
Name and address of the manufacturer :	SAFE Teknoloji San. ve Tic.Ltd.Sti. Güzelyurt Mahallesi 5775 Sk. No :30/A 45030 Manisa – Turkey
Test Report No :	P-IS-TGK-13-B-00816/01
Description of the Type example :	Pre-engineered SAFEGUARD fire extinguishing systems for protection of Commercial cooking equipment SG 70 060 0600 6,0 Lt SG 70 095 0800 9,5 Lt SG 70 145 1400 14,5 Lt SG 70 180 1600 18,0 Lt SG 70 250 2200 25,0 Lt
Manufacturing Plant :	SAFE Teknoloji San. ve Tic.Ltd.Sti. Güzelyurt Mahallesi 5775 Sk. No :30/A 45030 Manisa – Turkey
Tested according to :	UL300, NFPA 17A, NFPA 96 SAFEGUARD Installation, Maintenance & Recharge Manual No SAFE SG-F/12/2012 Effective 10.12.2012 Rev-C SAFE Fire Protection and Fire Testing Procedure of Commercial Cooking Equipment Hand Book. Effective 10.12.2012 Rev-C

This Attestation of Compliance is issued according to the Standards mentionend above relating to extinguishing systems for protection of commercial cooking equipment on a voluntary basis. It confirms that the listed type examples meet the requirements of the procedure for the testing of pre-engineered SAFEGUARD fire extinguishing systems for protection of commercial cooking equipment and applies to the sample and its technical documentation submitted to TÜV SÜD Türkiye for testing and certification.

Place
Istanbul Turkey

Date
10.11.2014

Signature
ÖZENÇ ÇETİN
TÜV SÜD TÜRKİYE

